

No: FB/R-4) 5735
Date: 13/04/2022

OFFICE OF THE CHIEF FIRE OFFICER
MUMBAI FIRE BRIGADE
Borivali Regional Command Centre
Link Road X Global Road Junction
Borivali (West), Mumbai - 400 092

Completion with respect to Inspection Report at M/s Swati Education Trust, Saibaba Nagar, Borivali (West), Mumbai 400 092

- Ref: 1. Letter from M/s Swati Education Trust dated 21.03.2022
2. Inspection Report - FB/R-4/OD/5655 dated 15.03.2022
3. MFB No. R-IV/5735 dated 21.03.2022

This is the completion with respect to previous issued Inspection Report along with recommendations / guidelines U/No. FB/R-4/OD/5655 dated 15.03.2022. During the Inspection, it was noticed that the recommendations / guidelines are complied with. However if any non-compliance of recommendations / guidelines is noticed in the premises after the inspection, then the inspecting officer or this department will not be responsible for the same.

However it is the duty/responsibility of owner/ occupier of the premises to maintain the fire prevention & life safety measures in good repair & efficient condition all the time in accordance with the provisions in Section 3 (1) of Maharashtra Fire Prevention & Life Safety Measures Act. If applicable the certificate in prescribed form (Form-B) from a Licensed Agency shall be submitted twice a year in the months of January & July, regarding the maintenance of Fire safety & life safety measures in accordance with the provisions in Section 3 (3), to the Nominated Officer / Chief Fire Officer.

The Party has submitted:

- Form "B" Certificate** under Maharashtra Fire Prevention & Life Safety Act 2006 issued by M/S Life Guard Enterprises, having license no. MFS/LA/RF-327, MFS/LA/RD-300 & MFS/LA/RP-59 for the period July 2021 to December 2021 regarding good working condition of the existing Fire Alarm & Smoke Detection system installed in the building.
- Form "B" Certificate** under Maharashtra Fire Prevention & Life Safety Act 2006 issued by M/s Hem Enterprises, having License No. MFS/LA/RF-0196 & MFS/LA/RD-175 for the period Sept 2021 to Sept 2022 for portable fire extinguishers.
- Electrical Test Report:** for electrical fittings/fixtures installed in the premises as per Electricity Act & Rules from Govt. approved electrical Inspector (M/s Sangeeta Electrical Works)

Note:

- This completion issued from fire safety point of view only, without prejudice to legal matters pending in court of law if any & inspection carried out by inspecting officer.
- Completion of the fire safety measures / recommendations / guidelines is for minimizing the chances of occurrence of the fire through active & passive fire safety measures. Any Non Compliance at any instance may cause occurrence of fire.
- The verification of Authenticity of structure, Mezzanine floor, Loft, Addition, Alteration, Change of user, Amalgamation, authorized / Unauthorized construction, Encroachment & Area of the premises is not under the purview of this department and will not be responsible for any illegality and its consequences thereof.

[Signature]
13/04/2022

Asstt. Div. Fire Officer
Mumbai Fire Brigade

C.C. to,

- M/s Swati Education Trust
- Office Copy

[Signature]
13/4/22

Dy. Chief Fire Officer
Mumbai Fire Brigade

[Signature]

MANAGER
JAYA INTERNATIONAL SCHOOL
BORIVALI (W)

[Signature]

PRINCIPAL
JAYA INTERNATIONAL SCHOOL
(Aff No 1130982 & School Code 30940)
BORIVALI (W)